



# EVPÜ<sup>®</sup>

NOTIFIED BODY No. 1293

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0669

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

**Fire detection and fire alarm systems**  
**Interactive addressable conventional line-monitoring input module**  
**with built-in isolators FD 7201S**

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

**UniPOS Ltd.**

**San Stefano str. 47, 5800 Pleven, Bulgaria**

and produced in the manufacturing plant

**UniPOS Ltd.**

**San Stefano str. 47, 5800 Pleven, Bulgaria**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

**EN 54-18:2005**  
**EN 54-18:2005/AC:2007**  
**EN 54-17:2005**  
**EN 54-17:2005/AC:2007**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate was first issued on January 20<sup>th</sup>, 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, January 20<sup>th</sup>, 2020  
053482

EVPÜ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, [www.evpu.sk](http://www.evpu.sk)  
Page 1 / 2 FCO 425-13 Rev.1

  
Marek Hudák  
Director NB

## Annex to Certificate No. 1293 - CPR – 0669 from January 20<sup>th</sup>, 2020

### Technical specifications:

Conventional line-monitoring module is designed to connect conventional fire alarm line (up to 32 fire detectors) to addressable fire alarm system type IFS 7000.

The module consists of a printed circuit board and a unit carrier, fixed in a plastic box.

The communication between the Fire Control Panel and the conventional line-monitoring module is completed via the specialized data exchange protocol UniTALK. Device address is programable from the Fire Control Panel IFS7002.

### Products parameters:


Supply voltage	15 ÷ 30 VDC
Operational temperature range	-10°C + +55°C
Relative humidity resistance	(93±3)% at 40°C
Degree of protection	IP 50
Dimensions	120 x 164 x 74 mm
Weight	0.200 kg

Essential characteristics	Harmonised technical specification		Performance
	EN 54-18:2005 EN 54-18:2005/ AC:2007	EN 54-17:2005 EN 54-17:2005/ AC:2007	
Response delay (response time)	cl. 5.2	---	Pass
Performance under fire conditions	cl. 5.1.4	cl. 5.2	Pass
Operational reliability	cl. 5.1.4	cl. 4	Pass
Durability of operational reliability: temperature resistance	cl. 5.3, 5.4	cl. 5.4, 5.5	Pass
Durability of operational reliability: vibration resistance	cl. 5.8 to 5.11	cl. 5.9 to 5.12	Pass
Durability of operational reliability: humidity resistance	cl. 5.5, 5.6	cl. 5.6, 5.7	Pass
Durability of operational reliability: corrosion resistance	cl. 5.7	cl. 5.8	Pass
Durability of operational reliability: electrical stability	cl. 5.2, 5.12	cl. 5.3, 5.13	Pass

### History of certification

No.	Certificate No.	Description	Date of issue
1	1293-CPD-0088	Original certificate issued	July 16 <sup>th</sup> , 2008
2	1293-CPD-0208	Added place of factory	January 10 <sup>th</sup> , 2011
3	1293-CPD-0281	Changed place of factory	March 9 <sup>th</sup> , 2012
4	1293-CPR-0669	CPR certificate issued Change of address	January 20 <sup>th</sup> , 2020

Nová Dubnica, January 20<sup>th</sup>, 2020



  
 Marek Hudák  
 Director NB