


Certificate





according to Low Voltage Directive 2006/95/EC

Certificate No.:

M1 69240071 0001

Report No.:

28208654 001

Certificate Holder:

Makrai Elektronik Bt.

Vám u. 3. 2600 Vác Hungary

Manufacturer:

Makrai Elektronik Bt.

Vám u. 3. 2600 Vác Hungary

Product:

TRANSFORMERS

Safety isolating transformers and isolating transformers

Identification:

Type ref.: ME.TRE-ab...

where: "a" = rated output

"b" = code of dimensions

Type variants detailed on Annex I.

Ratings: Rated output: (VA): 0,6..100

Upri: 24..400V,

Usec: 3-30V, 6-35V, 6-40V, 12-40V, 12-45V

(safety isolating transformers) 31-80V, 40-230V, 41-230V, 46-230V

(isolating transformers)

Tested according to:

EN 61558-1:1997+A1+A11

EN 61558-2-4:1997 EN 61558-2-6:1997

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements of Annex I of the Directive. The holder of the certificate is entitled to use this certificate for the declaration of conformity according to Annex III of the Directive. This certificate does not imply assessment of the production of the product and does not permit to use of a TÜV Rheinland or MEEI mark. The certificate is valid up to 3 years provided that the test specifications and construction of the product remain unchanged during this period.

Budapest, 2010.02.23

CE

Gabor Kassai

TÜV Rheinland — MEEI Kft. Certification — H-1132 Budapest, Váci str. 48/A-B — www.meei.hu
The CE marking may be used if all relevant and effective EC Directives are complied with





ANNEX I. to Certificate of Conformity No.: M1 69240071 0001 page 1 of 1

Type variants, technical data:

	KAA				Safety isolating transformers	Isolating transformers
Type	t _a [°C]	Isol. class	Upri [V]	Output [VA]	Rated secondary voltage [V]*	
ME.TRE-0,6.301XX	40/70	B/F	24-230	0,6	3-30	31-80
ME.TRE-1,2.302XX				1,2		
ME.TRE-1,8.303XX			24-400	1,8		
ME.TRE-2,4.304XX				2,4		
ME.TRE-2,7.305XX				2,7		
ME.TRE-3,5.306XX				3,5		
ME.TRE-4,5.381XX/Y	70	В	24-400	4,5	6-35	40-230
ME.TRE-6.382XX/Y				6		
ME.TRE-6.421XX/Y	70	В	24-400	6	6-35	40-230
ME.TRE-8.422XX/Y				8		
ME.TRE-10.481XXX/Y	70	В	24-400	10	6-40	41-230
ME.TRE-12.482XXX/Y			100-400	12		
ME.TRE-16.541XXX/Y	70	В	100-400	16	6-40	41-230
ME.TRE-20.601XXX/Y	70	В	100-400	20	6-40	41-230
ME.TRE-25.602XXX/Y				25		
ME.TRE-30.662XXX/Y	70	В	100-400	30	6-40	41-230
ME.TRE-40.663XXX/Y				40		
ME.TRE-47.664XXX/Y				47		
ME.TRE-60.753XXXX/Y	70	В	100-400	60	6-40	41-230
ME.TRE-75.754XXXX/Y				75	12-45	46-230
ME.TRE-100.84XXXX/Y	70	В	100-400	100	12-45	46-230
ME.TRE-20.601XX/BSS	60	В	100-400	20	12-40	41-230
ME.TRE-30.602XX/BSS				30		
ME.TRE-45.663XX/BSS				45		
ME.TRE-60.753XX/BSS				60	12-45	46-230
ME.TRE-75.754XX/BSS				75		
ME.TRE-100.84XX/BSS				100		

^{*}The rated secondary voltages are derived from series connection all secondary windings.

Explanation of marking:

transformer type ME.TRE output [VA]

"a" "b" code of dimension of transformer

X...: secondary voltage code

"N" without fixing means Y: construction code

provided with one fixing means "K" provided with two fixing means "KK"

"B" standing construction

fuse-link provided & standing construction "BSS"

Budapest, 2010.02.23.

Kassai Gábor