

Declaration of performance

№ 001/2014

According to Construction Products Regulation EU № 305/2011

1. *Unique identification code of the product-type:*

SIMPO

2. *Type Number:*

SIMPO

Description: **Intelligent interactive analogue addressable fire alarm control panel**

3. *Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer*

Fire detection and fire alarm systems installed in and around buildings

4. *Manufacturer*

**Teletek Electronics JSC
14A Srebarna Str.
1407 Sofia, Bulgaria**

5. *Trading Company*

**Teletek Electronics JSC
14A Srebarna Str.
1407 Sofia, Bulgaria**

6. *System of assessment*

System 1

7. *Notified Body*

**EVPU a.s.
19 Trencianska Str.
018 51 Nova Dubnica, Slovakia**

Notified Body Number

1293

EC Certificate Number

1293- CPR-0401

Teletek Electronics JSC

14A, Srebarna Str.
1407 Sofia, Bulgaria
www.teletek-electronics.com

Tel.: (+359 2) 969 47 00
Fax: (+359 2) 962 52 13
info@teletek-electronics.bg

Teletek
electronics

ISO 9001 Certified Company

8. *No European Technical Assessment has been issued for this product.*

9. *Declared performance*

EN 54-2:1997/A1:2006/AC:1999 Fire detection and fire alarm systems - Part 2: Control and indicating equipment		
Clause	Description	Performance
4, 5, 7	Performance under fire conditions	Pass
7.1, 7.7, 7.11, 7.12	Response delay (response time to fire)	Pass
4 to 10, 12, 13, 14	Operational reliability	Pass
15.4	Durability of operational reliability and response delay: - temperature resistance	Pass
15.6, 15.7, 15.15	Durability of operational reliability and response delay: - vibration resistance	Pass
15.8, 15.13	Durability of operational reliability and response delay: - electrical resistance	Pass
15.5, 15.14	Durability of operational reliability and response delay: - humidity resistance	Pass

EN 54-4:1997/A2:2006 /AC:1999 Fire detection and fire alarm systems - Part 4: Power supply equipment		
Clause	Description	Performance
4, 5, 6, 7, 8	Operational reliability	Pass
4, 5, 6	Performance of power supply	Pass
9.5	Durability of operational reliability and response delay: - temperature resistance	Pass
9.7, 9.8, 9.15	Durability of operational reliability and response delay: - vibration resistance	Pass
9.9	Durability of operational reliability and response delay: - electrical resistance	Pass
9.6, 9.14	Durability of operational reliability and response delay: - humidity resistance	Pass

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

1407 Sofia,
14A, Srebarna Str.
15.04.2014

Irina Georgieva
Quality Manager

